



**ADDENDUM #2
CAT 6 Cabling Routes - Jail**

To All Bidders:

Identified below are clarifications and additions to the original RFB and are hereby made part of the bid documents as fully and completely as if the same were fully set forth therein.

- For the camera mount in the walk in cooler, the wire should run through the top of the cooler to add the camera. Outagamie County Maintenance will seal up any holes as needed. The inside surface of the coolers is a thin sheet metal with foam insulation on the backside of the panels. For mounting the camera, go all the way through with bolts and using washers and nuts on the top side of the coolers so the camera cannot easily be knocked off the inside of the cooler.

Bidder must acknowledge Addendum #2 on the bid form. Failure to do so, may result in the rejection of your bid.

Issued:

September 5, 2024

Nicole Schoultz, Procurement Coordinator